


MICHAEL R. WALDBIESER



ENGINEERING & CONSULTING, INC.
STRUCTURAL, PLUMBING, MECHANICAL, & ELECTRICAL DESIGN



Michael R. Waldbieser PE
IN PE 19900108

Sycamore Building
19 South 6th Street, Suite 804
Terre Haute, Indiana 47807
Phone (812) 232-6510

August 15, 2018

**CITY OF TERRE HAUTE – DEPARTMENT OF REDEVELOPMENT
17 HARDING AVENUE, ROOM #301
TERRE HAUTE, INDIANA 47807
CENTRAL BUSINESS DISTRICT TIF LIGHTING 2018**

ADDENDUM #1

This ADDENDUM, giving information supplemental to the drawings and specifications, becomes part of the contract documents. Wherever this addendum might be in conflict with the drawings and/or specifications, this addendum shall take preference.

1. ALL BIDDERS: All bidders shall acknowledge receipt of this addendum on their bid forms.
2. GENERAL: The amount of existing sidewalk concrete to be removed to install new light pole bases shall be just enough to install new work. Entire sidewalk section panels do not need to be removed. Saw cut existing sidewalk in a square centered on new concrete light pole base.
3. GENERAL: It is known that one of the existing light poles provided by the Owner will require touch up paint after some rust removal. Include in the bid 2 square feet of rust removal and paint touch up. If more is required, a Change Order will be issued for additional work.
4. GENERAL: The City of Terre Haute Building Inspection Department will provide “No Parking” signs to be used by the Contractor to clear roadways for required construction. Movement of signs at the end of every day for next day’s work shall be by the Contractor.