

GREENCastle FIRE STATION EXTERIOR REPAIRS RE-BID

107 South Main Street
Greencastle, IN 46135

Prepared for:

The City of Greencastle

1 North Locust Street
Greencastle, IN 46135

Engineer/Architect:
ARSEE Engineers, Inc.
9715 Kincaid Drive, Suite 100
Fishers, IN 46037-9470



Philip R. Savich, P.E.

ARSEE ENGINEERS, INC.

CLIENT ORIENTED - BY DESIGN

9715 Kincaid Drive, Suite 100
Fishers, IN 46037-9459
FAX 317/594-9590
PHONE 317/594-5152

ADDENDUM No. 2

Issued: Monday, November 7, 2016

This addendum is issued in accordance with the provisions of Division 0 - Bidding and Contract Requirements of the Project Manual - Technical Specifications, and becomes a part of the Contract Documents as provided therein.

Acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject the Bidder to disqualification.

I. DRAWING CHANGES

A. None.

II. PROJECT MANUAL CHANGES

A. None.

III. QUESTIONS AND CLARIFICATIONS

A. Clarifications

C1: 4 inch XPS insulation shall be used in lieu of the specified 3 1/2 inch XPS insulation as the product is not available in the specified thickness.

IV. ATTACHMENTS

A. None.

END OF ADDENDUM 2