



## ADDENDUM NO. 1

Sullivan County Commissioner's Office  
Sullivan County EMS Garage  
1816 North Section Street  
Sullivan, Indiana 47882

September 8, 2016

TO ALL BIDDERS OF RECORD:

The following addendum indicated revisions, additions and deletions from the original construction documents dated August 18, 2016. This addendum forms a part of these documents. The original construction documents shall remain in entirety, except as modified by this addendum. The items herein supersede information in the drawings and project manuals.

Acknowledged receipt of this addendum by inserting its number on your bid proposal form. Failure to do so may subject the bidder to disqualification.

### **A. BID PROPOSAL FORM**

Bid Proposal Form to be submitted with contractor's bid package is attached to this addendum. Bid Proposal Form, is to be used in conjunction with CONTRACTOR'S BID FOR PUBLIC WORK – FORM 96.

### **B. CONSTRUCTION DOCUMENTS**

1. Sheet F1.0 – Foundation Plan & Sheet ALT F1.0 – Alternate Foundation Plan, Add Note 16, "Foundation sill plate anchor bolts shall be embedded a minimum of 7 inches into concrete or masonry and spaced not more than 6 feet apart in accordance with Section 2308.6, IBC.
2. Sheet S1.0 – Structural Framing Plan & Sheet ALT S1.0 – Alternate Structural Framing Plan, Add Note 10, "The size, height and spacing of studs shall be in accordance with Table 2308.6, IBC.
3. Sheet A1.0 – Architectural Floor Plan & Sheet ALT A1.0 – Alternate Architectural Floor Plan, Add Note 11, "Type I hoods should be installed where cooking appliances produce grease or smoke, such as occurs with griddles, fryers, broilers, ovens, ranges and wok ranges in accordance with Section 507.2.1, IMC.
4. Sheet E1.0 – Electrical Plan & Sheet ALT E1.0 – Alternate Electrical Plan, Add Note 16, "Contractor to provide electrical rough-ins for security system to be supplied by owner. Contractor to include an allowance of \$15,000 for security system rough-ins."

5. Sheet E1.0 – Electrical Plan & Sheet ALT E1.0 – Alternate Electrical Plan, Add Note 17, “Contractor to include an allowance of \$18,000 to furnish and install a natural gas generator and automatic transfer switch.”
6. Sheet E1.0 – Electrical Plan & Sheet ALT E1.0 – Alternate Electrical Plan, Add Note 18, “Wiring methods to include EMC in Garage with Romex wiring in Living Quarters.”
7. Sheet E1.0 – Electrical Plan & Sheet ALT E1.0 – Alternate Electrical Plan, Add Note 19, “Contractor to provide Exit and Emergency lighting over exterior doors.”
8. Sheet E1.0 – Electrical Plan & Sheet ALT E1.0 – Alternate Electrical Plan, Add Lighting Schedule as follows:

All Lighting to be manufactured by Lithonia

- a. Interior Garage Lighting – Linear Fluorescent / 28 Watt max
- b. Living Room Ceiling Lights – LED / 20.4 Watt max
- c. Interior Round Ceiling Lights – LED / 28 Watt max
- d. Bathroom Vanity Lights – Compact Fluorescent / 26 Watt max
- e. Ceiling Fan Lighting – 25.5 Watt max
- f. Exterior Wall Mounted Lighting – Compact Fluorescent / 13 Watt max

END OF ADDENDUM #1