

Addendum

PROJECT: Gillum Hall Second Floor Renovation

ADDENDUM # 2

DATE: 11/16/2015

TO: ALL INTERESTED BIDDERS OF RECORD

BID NUMBER: B0024204

This Addendum # 2 forms part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to acknowledge this Addendum may subject Bidder to disqualification.

GENERAL INFO

1. None

SPECIFICATION REVISIONS

1. None

DRAWING REVISIONS

1. None

QUESTION AND ANSWERS

- Q What accessories does restroom 215 receive? Do any of the existing restrooms receive any new accessories?
- A Room 215 will get an 18"x30" mirror and grab bars as required to meet ADA requirements. All other accessories will be provided by ISU and installed by Contractor. The other restrooms will not require any work.

OWNER COMMENT

1. Last day for questions has past. Any further questions received may not receive consideration.

End of Addendum # 2