



600 Wabash Ave.
Terre Haute, IN 47807
812.234.5190
812.234.7346 Fax

PROJECT: Indiana State University
Tech A Renovations for Built Environment
Offices

PROJECT NUMBER: 12014

DATE: February 26, 2013

PREPARED BY: Cari Rohrmayer

ADDENDUM

Number: FOUR

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

- A. Addendum Pages: ADD4-1 through ADD4-2 as prepared by MMS-A/E, Inc.
- B. Attachments: Questions and Answers

PART 1 - BIDDING & CONTRACT REQUIREMENTS

1.01 N/A

PART 2 - SPECIFICATIONS

2.01 N/A

PART 3 - DRAWINGS

3.01 N/A

PART 4 - GENERAL NOTES

4.01 N/A

ADD 4-1

Please acknowledge receipt of Addendum No. 1 on bid form.



600 Wabash Ave.
Terre Haute, IN 47807
812.234.5190
812.234.7346 Fax

PROJECT: Indiana State University
Tech A Renovations for Built Environment
Offices

PROJECT NUMBER: 12014

DATE: February 26, 2013

PREPARED BY: Cari Rohrmayer

Questions & Answers

- Q1. Sheet T201 look at all the note 17's will these apply to the non construction area?
A1. No. They are there for information only.
- Q2. On sheet T201, conference room 209, there is an "AV" symbol but on the detail sheets T406 and T407 it is not shown. Please clarify.
A2. See T100. Mount in floor below owners conference table.
- Q3. Also on sheet T201 in the same room there are 2 – "U" symbols. I think they are supposed to be "LI" and LI-c". Please clarify.
A3. Yes.
- Q4. Do you want 2 – Hubbell ZCB7UA zone boxes in the room or should it be just 1?
A4. One.